

Appendix 1

P. 1

NAME OF SCHOOL	DATE ASSESSED	ACCESSIBLE ENTRANCE	ACCESSIBLE PARKING	ACCESSIBLE PATHWAYS	ACCESSIBLE RESTROOM	COMMENTS
Brookline High School	3/29/18	<p>YES – there is directional signage, a ramp to the main entrance and the automatic opener is functioning. The 3rd floor entrance to the back of the school on Wellend Rd is also accessible. There is an accessible entrance on the 1st floor to Lowell Rd with an auto door opener.</p>	<p>YES – There are no HP spots at the front entrance, it is drop off/pick up only. There are 4 HP spots on Wellend Ave near the back entrance of the school.</p>	<p>MOSTLY – There are several elevators that give access to all floors spread throughout the school. The Auditorium on the 2nd floor has accessible seating, a lift to the stage as well as assistive listening devices available. Please test these devices every Sept and March. An Auto Door opener outside 257 should be installed on the Fire Doors. There is access to the Quad. There is ramp access and auto</p>	<p>SOMEWHAT – <u>Shluntz Gym downstairs</u>: both restrooms are accessible; however both Male and Female RR need signage. <u>1st Floor</u>: Restrooms on 1st floor are accessible and have correct signage. <u>2nd Floor</u>: The Gender Inclusive Bathroom is accessible but needs signage. Other Male and Female bathrooms on 2nd floor are accessible and signage is good. However the bathrooms by ACE have lips, which while not inaccessible, could</p>	<ul style="list-style-type: none"> • Tappen St Wing will be renovated. • SWS will be renovated • Consider Universal Design will all bathrooms and with new construction – have doors open into stalls.

			<p>doors to Schlutz gym. There is an elevator to the bathrooms downstairs. The Nurses Office on the 1st Floor has an accessible restroom in it. Outside the band room there is a lift that goes down 8 stairs that is self-operated or remote for someone to assist. We tested manually, and while it did get stuck it was human error. All students are shown the lifts and how to use if they are needed. There is Ramp access to the Cafeteria;</p>	<p>potentially be a barrier. 3rd Floor: Gender Inclusive bathroom is not accessible; although it has bars. Female bathroom in back corner is accessible and has correct sign. Men's bathroom in back corner is accessible but needs a sign. The Female bathroom by the Wellend Rd entrance has signage, and the stall is accessible, however the sink is in a 27in alcove which is not accessible. Recommended to remove sign or widen the area for the sink to 36 inches. The Men's Room closest to the Wellend Rd</p>	
--	--	--	---	---	--

Tappen Gym	3/29/18	YES – Ramp with rails to entrance and entrance accessible with automatic door function.	YES – 3 HP spots	while there is no designated wheelchair seating, the tables are high enough, however, the counters are too low. Recommend to raise counter seating.	entrance is accessible but needs correct signage. <u>4th Floor:</u> the RR near SWS is accessible, unisex and signage is good. The door is a bit heavy.	
			YES – Elevator makes all floors accessible.	SOMEWHAT – Girls Locker Rooms – has an accessible RR stall, and lockers are accessible; however, the changing rooms and showers are not accessible. If total accessibility by widening showers is not possible, it is recommended to make a shower chair available if needed. Boy's Locker		

						Rooms- RR is accessible and shower is accessible M Floor: Female RR is not accessible; no bars, only 28in clearance and door too heavy. Male RR is accessible, needs correct signage.	
Unified Arts Building	3/29/18		YES – Ramp entrance and auto door opening. Recommended to put rails on ramp.	NO specific parking	YES – Floors accessible via elevator.	YES - Basement – Bathroom is unisex and accessible, needs signage. 2 nd Floor – Female RR is accessible, however the heater should be moved as it narrows access to the stall, and signage is needed. Male RR has signage and is accessible.	
Baker	12/19/17		YES – Ramp access to main entrance with a	YES – There is designated accessible	YES – Aside from access to the Lower	YES – There are accessible staff, male and female	

		functioning automatic door opener. However there is no accessible entrance to the BSED Lower Extended Day via elevator or outside – there is a 4 in lip. Recommend a short ramp to make accessible.	parking at both accessible entrances.	Extended Day all other areas (floors and split levels) are fully accessible via elevator. The Library has an accessible entrance and counter and the auditorium has a lift to the stage.	bathrooms on all floors. However, a staff bathroom on the second floor (next to 220) needs appropriate signage.	
Devotion	UNDER CONSTRUCTION					Will do walkthrough in April or May of 2018.
Upper Devotion	11/18/17	YES – Ramp entrance to main floor with access to gymnasium and elevator to all other floors. Main entrance has an automatic door opener that needed fixing on day of	YES – There is one HP spot in front of the entrance.	YES – Elevators to all 3 floors are accessible. The auditorium, however, does not have ramp access to the stage.	MOSTLY – The male and female restrooms on the 1 st , 2 nd , and 3 rd floors are all accessible with appropriate signage. However, the boys bathroom on the main ground floor has an accessible stall, no signage and an	Used as extra school space.

Driscoll	11/8/17	assessment. Work order was placed 11/19/17. YES – Ramp access to main entrance and functioning automatic doors.	YES – There is 1 HP van accessible spot in back of school with accessible entrance. Automatic opener to parking entrance needs to be fixed; not functioning properly.	YES – There is elevator access (not locked when I visited) to all levels. There is a steep ramp to the gym and an accessible entrance to the playground. The theater has a chair lift access as well as a ramp to the stage.	inaccessible hallway to access restroom (only 27.5 in in width) NO -- There is one staff bathroom on the main floor that is accessible. Student bathrooms on all levels are not accessible. There is one female bathroom with a lift and mat for changing a particular student. It is recommended that 1 student bathroom on each floor be made accessible.	Last renovated in 80's
Heath	12/19/17	YES – There are a network of smooth ramped walks to the main entrance with a functioning automatic door.	YES – there are 2 HP spots in front of the main entrance.	YES – there is ramp and elevator access to all areas. There is a ramp to the auditorium from the cafeteria. Auditorium has WC seating and	NO – On the main floor there is a Girls room in the cafeteria that is NOT accessible; there is a Boy's room outside the cafeteria that is NOT accessible. There is a gender	

Lawrence	11/8/17	YES -- the main entrance is accessible, without the use of stairs or ramps. Main Entrance uses an automatic door.	YES -- There is one spot in front of main entrance.	MOSTLY -- side entrances lead to stairwells. 2 elevators. One elevator gives access to basement, 1 st floor and 2 nd floor. The elevator with access to the 3 rd floor is only 25 inches wide and is too narrow for wheelchair access. Access to Cafeteria, Gym and Auditorium via ramps.	bathrooms accessible. YES -- Male and Female restrooms on first, 2 nd , 3 rd floors and basement are accessible. Locker/restrooms in basement are accessible but need signage	Renovated in 2005
Lincoln	11/8/17	YES -- there are 3 accessible entrances in the front of the building. Entrance door is automatic. Needed fixing on day of	YES -- There is a HP van spot in the front of the roundabout in front of main entrance.	YES -- all learning areas are accessible. There is elevator access to all floors (not locked and functioning). Typical	YES -- all restrooms on all three floors have accessible stalls. However ALL restrooms need universal signage to indicate accessibility.	Built in 1992

Pierce	10/5/17	<p>Assessment.</p> <p>YES - Main entrance is only accessible entrance; all paths to get to entrance area from drop off area are accessible via a sloped switchback. Entrance door is automatic.</p>	<p>YES - There is no HP Parking specifically for school above ground, but there is HP parking designated in Town Lot and underground parking garage.</p>	<p>classroom set ups. From the cafeteria there is an access to the play area via paved ramp.</p> <p>YES - Auditorium has designated W/C seating; Elevator (not locked and functioning) or ramp access to all main areas of the hive except for solitary lofts; open classroom format allows for no fixed seating.</p>	<p>Yes, but -</p> <p>1) Cafeteria bathroom has 1 fully accessible stall in male and female restroom; needs signage</p> <p>2) Hive bathrooms on 1st and 2nd floors - not accessible</p> <p>3) Nurses Office - not accessible</p> <p>4) 2nd Floor bathroom off Rm 218 - single unisex bathroom with 17" toilet, grab bars and compliant clearance inside and outside; needs signage</p>	<p>The Historic Building does have an accessible entrance, an ADA compliant bathroom on 1st floor, but does not have an elevator to second floor.</p>
Runkle	2/5/18	<p>YES - there is access to the main entrance without the</p>	<p>YES - There are 2 HP spots in front and a specific loading</p>	<p>YES - main elevator goes to all floors and sub-levels. Via</p>	<p>YES - On the 1st, 2nd, 3rd and sublevel floors the Male and Female</p>	<p>2012 New Construction</p>

		<p>use of ramps. Automatic doors are properly functioning.</p>	<p>zone in the driveway for HP vehicles.</p>	<p>lifts, ramps and sublevel entrances, the courtyard, cafeteria and playground are accessible. The cafeteria has moveable tables. Back access to the playground is kept locked, but the auto door opener does work and we discussed keeping that access point open during the day. The multipurpose room has no fixed seating and has a ramp to the stage. There are accessible lockers on the 3rd floor.</p>	<p>RR's are accessible with correct signage. Gender Neutral Single bathrooms are also available.</p>	
--	--	--	--	---	--	--