

Appendix 3

NAME OF PARK	DATE ASSESSED	ACCESSIBLE ENTRANCE	ACCESSIBLE PARKING	ACCESSIBLE PATHWAYS	ACCESSIBLE PLAY SURFACE	ACCESSIBLE RESTROOM	COMMENTS
Amory Park	7/12/17	Yes - 2	Yes - 4 in parking lot	Yes - Loop	Yes - Tennis Court	No	Renovated in 2007
Brookline Ave							Under construction
Cypress St	9/20/17	Yes - 2	Street Parking only.	Yes - Pathway across to connect entrances: to playground and basketball court.	Yes - Somewhat; access points to play on slide. Swings and water play not accessible.	No	Slated for work in 2 years.
Daniel J Warren/Eliot	7/12/17	Yes - 2	Yes - 2 in parking lot	Yes - Loop	Yes - All (swing, sand and water play and picnic tables)	Exterior Access to Rec Dept Restrooms	None
Harry Downes Field	7/12/17	No, 5 entrances, only 1 is moderately accessible. The rest are high grade, not even surfaces, on grass, etc	No - No parking lot, all street parking	No - but the synthetic track has one accessible access point	Yes - somewhat; access points to play	Yes - but no signage	Will be renovated within 2 years; design process started.
Putterham Golf Course	10/11/17	Yes - 2	Yes - 3	Yes	Yes - Accessible Golf Carts can access the driving range and golf course	Yes	In depth assessment under Recreation Department facilities.
Skyline Park	9/20/17	Yes - 2; 1 to field, path and restrooms, the	Yes - 3	Yes	Yes - port a play and HC Swing	Yes - but no signage	Prior landfill, new park



Soule Recreation Center Playground	9/20/17	other to play and picnic area. Yes - 1	Yes - 2 Accessible spots	Path into playground accessible from front, path to gym not accessible Yes - Loop around tennis court	Yes - HC swing, accessible water play; woodchips in areas. Yes - port a play path to 2 HC Swings and accessible water play feature	Yes - 2 unisex, accessible bathrooms - but no signage.	Work to be done after Baldwin Study
Waldstein Playground	7/12/17	Yes - 3 accessible entrances, all paved surfaces with ramps no greater than 1:12 slope.	No - No parking lot, all street parking	Yes - Loop around tennis court	Yes - port a play path to 2 HC Swings and accessible water play feature	Yes	Was renovated in 2014-2015
Brookline Reservoir Park	10/11/18						Currently there are no accessible entrances. This Park is to be renovated with 3 accessible entrances and a unisex accessible bathroom facility.
Emerald Necklace (1) Riverway	7/12/17	Yes - Longwood on D line has full ramp access; Carlton St footbridge is being replaced	No - No parking	Yes - bike/pedestrian shared use pathways are asphalt.	No play area	No restroom	Linear park. Sections have and are being worked on currently to improve

									accessibility.
Emerald Necklace (2) Olmsted Park	7/12/17	Yes	Yes – 2HC spots in main lot	Yes – 9 foot separated pedestrian and bike paths; new ADA accessible crosswalk to connect parks	No play area	No restroom	Linear park.		
Larz Anderson Park	9/20/17	Yes – accessible entrance from Goddard Ave Lot and accessible entrance from Main Entrance; picnic pavilion is accessible	Yes – Goddard Ave Lot has 2 HC spots, but no access aisles. The main entrance has 2 van accessible spots with ramp access to the skating rink.	Somewhat - 1 out of 2 bridges are accessible; some pathways are deteriorated and pathways to not extend to multiple parts of park.	Yes - Playground is accessible from Goddard Ave Lot with port a play access to HC swing.	Yes - Goddard Lot Restroom is HC unisex/family use – toilet seat only 15in high. Needs to be 17; everything else compliant Skating Rink bathrooms – both men’s and women’s have an accessible stall.	Active and passive park, historic land site. Looking to retrofit the building near the Goddard Ave Lot in 4-5 years. Also looking to make perimeter walking paths more accessible and create a network of paths to be done in stages.		
Longwood Mall	11/9/17	No – curb cuts at Chatham and Beech for sidewalk access. No accessible entrance or path to park –	No – Street parking only	No – no paths at all. All grass.	No play area	No restroom	Passive park with no pathways or fixed seating.		

		all grass.							
Billy Ward Playground	7/12/17	Yes - 2 accessible entrances	No - No parking lot. Street parking only	Yes - ramp accessible to leveled play areas.	Yes - Play and waterpark accessible	No restroom	Renovated in 2013/14		
Boylston St. Playground	11/7/17	Somewhat - There is a curb cut and paved entrance from Boylston St to basketball and play, however entrance from street to field is not accessible.	No - Street parking only	Somewhat - paved ramp to basketball court, play area and accessible water fountain. Ramp somewhat steep and in need of repair in some places. Lower picnic area next to play area is not accessible.	No - No HP swing, only 1 port o play access to equipment, and majority woodchip play area.	No restroom			
Clark Playground	8/27/18	Yes - accessible from Mulfred and Edwin Sts.	No parking	Yes - there is a paved seating area with tables; 2 out of the 3 are accessible. There is a paved loop around the greenspace. There is an accessible picnic bench	Mostly - water play is accessible and the play area is in woodchips with a port a play access. There are no HP swings.	No restroom			

Judge Summer Z Kaplan Park at Coolidge Playground	11/20/17	Yes – there are 4 main entrance points. 2 from Kenwood and 2 from Russell St. All are paved access with sufficient curb cuts from street; however one access from Russel St is at a light slope.	No –Street parking only	and the basketball blacktop is accessible. Somewhat – there is no access to picnic area, it is all on grass. There is no access to tennis court due to a lack of curb cut and no level entrances. There is paved access to the BB court and the rest of the park is paved walkways.	Somewhat – There is access to water play and paved access to sand play. However the play equipment is on port o play and wood chips with no access to swings and no HP swing.	No restroom		
Daniel Ford Playground at Emerson Garden	8/1/18	Yes – all 3 entrances are accessible	No parking	Yes – There is a paved path that loops the park with an accessible water play area and accessible seating; 2 seating benches with concrete 36' space next to them; picnic tables with	Somewhat – The play area is surrounded by wood chips (not an accessible material to travel over). The large Port-a-play area has sloped and curved access to the higher level play area. However there	No restroom		The whole park is wonderfully designed; however the wood chips and the 3.5" level change to the wood structure make it inaccessible/not functional for disability population.

				<p>accessible cut outs.</p>	<p>is a 3.5" level change to access wooden play structure making it not accessible and also a tripping hazard. The sand play pit has a slight port a play slope to make it somewhat accessible.</p>		
<p>Griggs Park</p>	<p>11/21/17</p>	<p>Somewhat – there are 3 accessible entrances; 1 is too steep.</p>	<p>No parking</p>	<p>Somewhat – passive, paved loop path, however uneven and broken in places with bumps that would be hazardous for wheelchairs. A water fountain off the path is accessible. All picnic tables on grass and not accessible.</p>	<p>No – No access to BB court, no access to sand box, playground is all woodchips, there are no HP swings and the climb play is inaccessible.</p>	<p>No restroom</p>	
<p>John E Murphy Playground</p>	<p>7/12/17</p>	<p>Somewhat – grade is a bit steep</p>	<p>No parking</p>	<p>Somewhat - Broken concrete,</p>	<p>Somewhat – mulch play areas.</p>	<p>No restroom</p>	<p>Bowl shaped no renovations in last 30 years, in</p>

				mostly field; grade of paths steep.				CIP for next 4 years.
Juniper St. Playground	Not completed for this assessment							
Lawton Playground	8/7/18	Yes – Community garden and basketball court are accessible. Main park entrance is accessible, however some stones are corroded. Gibbs St. entrance is also accessible.	No parking	Yes – there are paved access points and a paved pathway that leads through the park and to benches.	Somewhat – Raised beds in the community garden are accessible, the Main play area is off a curb and in wood chips, making it not accessible. The sand play is depressed and there is no level access provided. The water play area is level and accessible.	No restroom		
Lotta Bradburn Schick Park	8/21/18	Somewhat – Main entrance is up a flight of stairs, no signage directing people to accessible entrance. The ramp entrance is completely	No Parking	Somewhat – the path to the basketball court is accessible. The path behind the basketball hoop is not wide enough. The path to the	Not really – the tire swing and regular swings are over woodchips and off a curb. The slides and play area are in wood chips and down three	No restroom		

Playground											
Driscoll School Playground	7/12/17	Yes	No parking	Somewhat - Hard top in need of repair	Yes - Play park is compliant, has HC swings and a compliant water fountain.	No restroom					
Heath School Playground	7/12/17	Yes	Yes - 2 HP spots	Somewhat - accessible path to port in place play area with timber edges - Needs upgrade. 5-12 yrs play space is hardtop and accessible soft tile. Accessible from school.	Yes	No restroom					
Longwood Playground	Not completed for this assessment										
Pierce School Playground	11/29/17	Somewhat - Small playground has accessible entrances; large playground has 1 accessible access point on School St, 2 accessible access points on Harvard Ave, however the	No parking	Yes - looped paths around large main playground are accessible, paved and not drastically sloped with 1 accessible picnic area.	Somewhat - small playground is accessible with port a play. Large playground has access to BB court, and water play. There is one port a play access point to	No restroom					

			overpass from Pierce School is NOT accessible; stairs only.		No parking		older play are and giant slide and 1 port a play access point to younger play area. There are no HP swings and there is no accessible access point to the tire swing park.			
Runkle School Playground	7/12/17		Yes – ramp access and entrance from school	No parking	Yes – smooth paved ramp access to both levels	Yes – larger play area all port a play with HC swing. Kindergarten play space also accessible with HC swing.	No restroom	Reno 2013		
Lincoln School Playground (New)	Not completed for this assessment									
Lincoln School Playground (old)	Not completed for this assessment									
Corey Hill Park										Under construction
Dane Park	9/20/17		Yes – paved path entrance	No – no parking	Somewhat – paved path and	No playground – wooded	No restroom	Improved 10 years ago		

Eliot St Park	7/11/18	Somewhat – Entrance via 1 curb cut; rest of park surrounded by a curb.	No – no parking	loop (wood chip path in some parts) No – No paved paths	passive park, no play equipment No playground – passive park/field.	No restroom	
Knyvet Park	7/12/17	Yes – curb cuts and paved access points	No – no parking	Yes – cross passive park with paved walkways	No playground	No restroom	
Linden Park	7/12/17	Yes - 2	No – no parking	Yes – small passive park path between 2 access points with bench seating	No playground	No restroom	
Linden Square	7/12/17	Yes - 2	No – no parking	Yes – circle passive park with 2 accessible points with curb cut access	No playground	No restroom	
Mason Square	7/19/18	No	No –No Parking	No	No playground	No restroom	Passive Park with no curb or sidewalk access, on a hill, no paths or seating areas.
Monmouth St Park	7/10/18	Yes – 2 out of 3; the main entrance and	Yes – there is 1 spot in front of Brookline Arts	Yes – there is a fully paved in/out path to	No – play area is on port a play, no HP	No restroom	

		the St. Mary's entrance are accessible	Center off of Monmouth St.	<p>port a play and there is a fully paved route through the park is mostly level.</p> <p>Seating – Yes – 4 out of the 6 benches have a 36" clearance next to them for W/C.</p>	access		
Philbrick Square	Not completed for this assessment 7/12/18	Yes – 2 out of 3 accessible entrances; both corners of Park St.	Yes – there is 1 HP spot at the corner of Vernon – this is the only inaccessible park entrance. This spot should be moved.	Somewhat – there is an accessible concrete path that loops through park; however there are a lot of cracks and gaps that should be filled in. There are many benches and some do have the 36" clearance for a W/C to fit next to them. There are 3 accessible	No Play area	No restroom	
Judge Henry Crowley Park at St. Mark's Square							



Town Hall Lot	7/23/18	Yes - 2 accessible access points; one from the parking lot and one from Washington St.	Yes - there are 4 HP spots in the Town parking lot that is adjacent to green space.	table tops with no fixed seating. Somewhat - benches in some areas have a 36' clearance adjacent, the ones lining the Washington St entrance, do not. There is a paved brick walk to green space with seating benches. There is a broken gravel/rock path to picnic areas, however tables are not accessible. The gravel path also leads to steps to the monument - which is not accessible.				
D. Blakely Hoar Sanctuary	Not completed for this assessment							

Hall's Pond Sanctuary and Amory Woods	7/12/17									
Lost Pond Conservation Area	Not completed for this assessment									
Lost Pond Reservation	Not completed for this assessment									
Fisher Hill Reservation	7/12/17	Yes - main entrance is accessible	Yes - 2	Yes - full network of accessible paths.	No playground	Yes - 2 single occupancy	Reno in 2016			